

# NEXTERA ENERGY



RESOURCES

## EXCELSIOR ENERGY CENTER ELECTRIC AND MAGNETIC FIELD (EMF) CALCULATION

Revision A

PRELIMINARY – NOT FOR CONSTRUCTION

Project No.: 13666-053

55 East Monroe Street  
Chicago, IL 60603-5780 USA  
312-269-2000  
[www.sargentlundy.com](http://www.sargentlundy.com)




## ISSUE SUMMARY AND APPROVAL PAGE

This is to certify that this Electric and Magnetic Field (EMF) Calculation has been prepared, reviewed and approved in accordance with Sargent & Lundy's Standard Operating Procedure SOP-0405, which is based on ANSI/ISO/ASSQC Q9001 Quality Management Systems.

### CONTRIBUTORS

Prepared by:

 Justin Steiner Associate	07/14/2020 Date
--	--------------------

Reviewed by:

Kunhal Parikh Senior Associate	07/17/2020 Date
-----------------------------------	--------------------

Approved by:

Kunhal Parikh Project Manager	07/17/2020 Date
----------------------------------	--------------------



## **TABLE OF CONTENTS**

EXECUTIVE SUMMARY .....	1
1.0 PURPOSE AND SCOPE.....	2
2.0 DESIGN INPUTS.....	3
3.0 RESULTS .....	8
4.0 REFERENCES .....	13

## **LIST OF TABLES**

TABLE 1 - PROPOSED LINE CONDUCTOR PROPERTIES .....	3
TABLE 2 - PROPOSED LINE UNDERGROUND CABLE PROPERTIES.....	3
TABLE 3 - PROPOSED LINE RATING OUTPUT SUMMARY .....	4
TABLE 4 - EMF RESULTS.....	8

## **LIST OF FIGURES**

FIGURE 1 - EXISTING CONFIGURATION .....	5
FIGURE 2 - PROPOSED CROSS SECTION 1 .....	6
FIGURE 3 - PROPOSED CROSS SECTION 2 – UNDERGROUND CABLES .....	6
FIGURE 4 – PROPOSED SITE PLAN .....	7

## EXECUTIVE SUMMARY

NextEra Energy Resources (NEER) (Owner) has requested Sargent & Lundy, L.L.C. (S&L) to provide engineering services for a 345kV transmission line tap line associated with the proposed Excelsior Energy Center. The project is located in Genesee County, New York; the line is less than 500 ft. The 345kV transmission line has one (1) cross section, as shown in the report below. The 34.5 kV collection cable maximum fields will be generated near the proposed collection substation and will have one (1) cross section.

As part of the deliverables, S&L will determine the electric and magnetic fields (EMF) for the Winter Normal ratings per the New York Independent System Operator (NYISO) Tie-line Rating Report. The calculation will be used to determine the maximum electric field (kV/m) and magnetic field (mG) within and at the edge of the right-of-way (ROW) for the transmission line and underground collection cross sections.

## 1.0 PURPOSE AND SCOPE

### 1.1 DESCRIPTION

The purpose of this calculation is to determine the electric and magnetic fields (EMF) for the ratings listed below and calculated per the New York Independent System Operator (NYISO) Tie-line Rating Report.

### 1.2 ELECTRIC AND MAGNETIC FIELD GUIDELINES

New York State Public Service Commission (NYPSC) set forth in Opinion and Order Determining Health and Safety Issues, Imposing Operating Conditions, and Authorizing, in Case 26520, Operation Pursuant to those Conditions No. 78-13 and Statement of Interim Policy on Magnetic Fields of Major Electric Transmission Facilities, NYPSC Cases 26529 and 26559, sets the guidance for electric and magnetic fields, respectively.

These opinions and cases set forth the requirement of the minimum electric and magnetic fields at the edge of the ROW. The electric fields strength by the proposed transmission line will not be greater than 1.6 kV/m at the edge of the ROW and measured, one meter (3.28 ft) above ground level, with the line at the rated voltage. The magnetic field strength by the proposed transmission line will not be greater than 200 mG at the edge of the ROW, measured at one meter (3.28 ft) above grade. The limits for the electric and magnetic field strength will adhere to the requirements set forth by the NYPSC [1]. The determination of the phase currents will be based on the Winter Normal rating from the NYISO Tie-line Rating Report. Finally, the conductor height will be calculated under normal conductor temperature (95°C).

## 2.0 DESIGN INPUTS

### 2.1 UNVERIFIED INPUTS

**Table 1 - PROPOSED LINE CONDUCTOR PROPERTIES**

Properties	Conductor	Overhead Shield Wire (OHSW)
Type	ACSR	EHS STEEL
Size	795 kcmil	3/8"
Stranding	26/7	7-Strand
Diameter (in)	1.107	.36
Conductor Cross Sectional Area (in <sup>2</sup> )	0.7263	N/A
Weight (lbs/ft)	1.093	0.273
Rated Tensile Strength (lbs)	31,500	15,400
Sub-conductor Horizontal Spacing (in)	N/A	N/A
Resistance, DC, 20°C (Ω/1000 ft)	.0214	N/A
Resistance, AC, 75°C (Ω/1000 ft)	.0263	N/A

\*Properties from General Cable

**Table 2 - PROPOSED LINE UNDERGROUND CABLE PROPERTIES**

Properties	Conductor
Type	XLPE
Size	1250 KCMIL
Stranding	N/A
Diameter (in)	2.458
Conductor Cross Sectional Area (in <sup>2</sup> )	0.98186
Weight (lbs/ft)	~2.7

\*Properties from General Cable

**Table 3 - PROPOSED LINE RATING OUTPUT SUMMARY**

Case	Rating Condition	Thermal Rating (Amperes)
1	NYISO – Winter – Normal	1500 (estimated)
2	NYISO – Winter – STE	1500 (estimated)
3	NYISO – Summer – Normal	1500 (estimated)
4	NYISO – Summer – STE	1500 (estimated)
5	Underground Cable – 1250 kmil	669.40

Soil Conditions:

The geotechnical resistivity provided by the geotechnical report was calculated to be 73  $\Omega\cdot\text{m}$ . The calculation utilized a conservative value of 100  $\Omega\cdot\text{m}$ . The noted ground resistivity was then converted into the required ground conductivity input value as follows:

The inputs to the Bonneville Power Authority (BPA) program (version 3.1) require the ground conductivity to be entered ( $\text{mmhos}/\text{m} = \text{mS}/\text{m}$ ). Therefore, the reciprocal of the ground resistivity of 100  $\Omega\cdot\text{m} =$  the ground conductivity of 10.0  $\text{mS}/\text{m}$

Electric Field Shielding

Shield from objects was not considered as part of this calculation.

Conductor Phasing

Conductor Phasing for the typical steel monopole tangent structure, conductors A, B, and C are assumed to be on the top arm, middle arm, and lower arm, respectively. It is assumed that phasing will produce the highest electric and magnetic fields.

Conductor Midspan Height

For proposed lines, the conductor midspan height was assumed to be at worst case sag with conductor at a temperature of 203°F (95°C). For existing lines, the conductor midspan height was assumed to be at a minimum NESC clearance to ground.

### SW Midspan Height


Shield wire midspan height was assumed to be at 75% of the conductor sag at average ambient temperature (49°F).

### Ground Elevation

The ground elevation is less than 1000 ft and will be inputted as 0 ft based on the recommendation of the BPA program.

### Existing Conductor Configuration

There are no existing cross sections for the existing NYPA 345 kV transmission line. The minimum clearance to ground for the 345 kV transmission lines is 28 ft.




**Figure 1 - EXISTING CONFIGURATION**



Cross Section 1


The proposed cross section consists of the 345kV transmission lines. The ROW width is 250 ft.



**Figure 2 - PROPOSED CROSS SECTION 1**

Cross Section 2

The proposed cross section consists of twelve (12) 34.5 kV underground cables for the collection system. The ROW width is 150 ft.



**Figure 3 - PROPOSED CROSS SECTION 2 – UNDERGROUND CABLES**



**Figure 4 – PROPOSED SITE PLAN**

### 3.0 RESULTS

#### 4.1 EMF RESULTS TABLE

The EMF results shown are for the proposed 150' ROW by NextEra Energy Resources (NEER).

**Table 4 - EMF RESULTS**

Case Designation	EMF at Edge of ROW	NYPSA Criteria at Edge of ROW
<b>Electric Field (kV/m)</b>		
Existing ROW Cross Section 1	n/a	1.6 kV/m
Proposed ROW Cross Section 1 – Winter Normal	0.223	1.6 kV/m
Proposed ROW Cross Section 1 – Winter STE	0.223	1.6 kV/m
Proposed ROW Cross Section 1 – Summer Normal	0.223	1.6 kV/m
Proposed ROW Cross Section 1 – Summer STE	0.223	1.6 kV/m
Proposed Row Cross Section 2 -Maximum Load	N/A	N/A
<b>Magnetic Field (mG)</b>		
Existing ROW Cross Section 1	n/a	200 mG
Proposed ROW Cross Section 1 – Winter Normal	72.63	200 mG
Proposed ROW Cross Section 1 – Winter STE	72.63	200 mG
Proposed ROW Cross Section 1 – Summer Normal	72.63	200 mG
Proposed ROW Cross Section 1 – Summer STE	72.63	200 mG
Proposed ROW Cross Section 2 – Maximum Load	7.2	200 mG


In conclusion, the results of the study show that the calculated electric and magnetic fields are acceptable when compared to the electric fields requirement of 1.6 kV/m, one meter (3.28 ft.) above ground level, and the magnetic field strength requirement is 200 mG, measured at one meter (3.28 ft.) above grade, at the existing NYPA and proposed Excelsior Energy Center transmission lines edge of ROW.


See Appendix A for the inputs and results of the (BPA) Corona and Field Effects computer programs.

Finally, Stipulation 35 – Section (d) – the study to evaluate potential induced voltages on Project Components located in proximity to high voltage electrical transmission facilities cannot be determined at this stage. The substation perimeter fence will be grounding in accordance to Institute of Electrical and Electronic Engineers (IEEE) standards and the design drawings. Adjacent fencing is not proposed at this time. Should fencing outside of the substation perimeter fence be required applicable codes and standards associated with the transmission line will be evaluated.


## 4.2 EMF PLOTS

### Cross Section 1





Cross Section 2



#### 4.0 REFERENCES

1. STATE OF NEW YORK PUBLIC SERVICE COMMISSION CASES 26529 and 26559 - Proceeding on Motion of the Commission as to Regulations Regarding Electric and Magnetic Field Standards for Transmission Lines – Statement of Interim Policy on Magnetic Fields of Major Electric Transmission Facilities (Issued and Effective: September 11, 1990)
2. STATE OF NEW YORK PUBLIC SERVICE COMMISSION OPINION NO. 78-13 - Opinion and Order Determining Health and Safety Issues, Imposing Operating Conditions and Authorizing, in Case 26529, Operation Pursuant to those Conditions (Issued June 19, 1978)
3. New York Power Pool – Tie-Line Rating Task Force – Final Report on Tie-Line Rating (Approved November 1995)
4. EPRI AC Transmission Line Reference Book – 200 kV and Above, 2015 Edition (3002005659 Update November 2015)
5. NYISO 2016 Load & Capacity Data, “Gold Book” (Released April 2016)
6. National Electrical Safety Code (NESC) - 2017 Edition (C2-2017)



Appendix A: EMF Study (ROW Cross Sections 1 & 2)

MAGNETIC FLUX DENSITY [mG]  
 =====

Study : Excelsior Energy Center Ampacity Study  
 Execution: Cable in Trench (1250kcmil 11')

X (feet)	Y=0.0 (feet)	Y=1.0 (feet)	B(mG)	B(mG)
-500			0.0046	0.0046
-495			0.0047	0.0047
-490			0.0048	0.0048
-485			0.0049	0.0049
-480			0.005	0.005
-475			0.0051	0.0051
-470			0.0052	0.0052
-465			0.0053	0.0053
-460			0.0055	0.0055
-455			0.0056	0.0056
-450			0.0057	0.0057
-445			0.0058	0.0058
-440			0.006	0.006
-435			0.0061	0.0061
-430			0.0062	0.0062
-425			0.0064	0.0064
-420			0.0066	0.0066
-415			0.0067	0.0067
-410			0.0069	0.0069
-405			0.007	0.007
-400			0.0072	0.0072
-395			0.0074	0.0074
-390			0.0076	0.0076
-385			0.0078	0.0078
-380			0.008	0.008
-375			0.0082	0.0082
-370			0.0084	0.0084
-365			0.0087	0.0087
-360			0.0089	0.0089
-355			0.0092	0.0092
-350			0.0094	0.0094
-345			0.0097	0.0097
-340			0.01	0.01

-335	0.0103	0.0103
-330	0.0106	0.0106
-325	0.0109	0.0109
-320	0.0113	0.0113
-315	0.0116	0.0116
-310	0.012	0.012
-305	0.0124	0.0124
-300	0.0128	0.0128
-295	0.0133	0.0133
-290	0.0137	0.0137
-285	0.0142	0.0142
-280	0.0147	0.0147
-275	0.0153	0.0153
-270	0.0159	0.0159
-265	0.0165	0.0165
-260	0.0171	0.0171
-255	0.0178	0.0178
-250	0.0185	0.0185
-245	0.0193	0.0193
-240	0.0201	0.0201
-235	0.0209	0.0209
-230	0.0219	0.0219
-225	0.0228	0.0228
-220	0.0239	0.0239
-215	0.025	0.025
-210	0.0262	0.0262
-205	0.0275	0.0275
-200	0.0289	0.0289
-195	0.0304	0.0304
-190	0.0321	0.032
-185	0.0338	0.0338
-180	0.0357	0.0357
-175	0.0378	0.0378
-170	0.0401	0.04
-165	0.0425	0.0425
-160	0.0452	0.0452
-155	0.0482	0.0482
-150	0.4726	0.0515
-145	0.5865	0.0551
-140	0.7475	0.0591
-135	0.9862	0.0636
-130	1.3628	0.0686
-125	2.0096	0.0742
-120	3.2676	0.0805
-115	6.2276	0.0877
-110	15.3098	0.0959
-105	29.9743	0.1052

-100	4.9127	0.1161
-95	29.9742	0.1287
-90	15.3098	0.1435
-85	6.2276	0.1609
-80	3.2676	0.1818
-75	2.0096	0.2071
-70	1.3628	0.238
-65	0.9862	0.2765
-60	0.7475	0.3251
-55	0.5865	0.3878
-50	0.4726	0.4707
-45	0.5865	0.5835
-40	0.7475	0.7426
-35	0.9862	0.9776
-30	1.3628	1.3458
-25	2.0096	1.9711
-20	3.2676	3.16
-15	6.2276	5.8076
-10	15.3098	12.6568
-5	29.9743	19.3417
0	4.9127	0.7854
5	29.9742	19.3417
10	15.3098	12.6568
15	6.2276	5.8077
20	3.2676	3.16
25	2.0096	1.9711
30	1.3628	1.3458
35	0.9862	0.9776
40	0.7475	0.7426
45	0.5865	0.5835
50	0.4726	0.4707
55	0.4726	0.3878
60	0.5865	0.3251
65	0.7475	0.2765
70	0.9862	0.238
75	1.3628	0.2071
80	2.0096	0.1818
85	3.2676	0.1609
90	6.2276	0.1435
95	15.3098	0.1287
100	29.9743	0.1161
105	4.9127	0.1052
110	29.9742	0.0959
115	15.3098	0.0877
120	6.2276	0.0805
125	3.2676	0.0742
130	2.0096	0.0686

135	1.3628	0.0636
140	0.9862	0.0591
145	0.7475	0.0551
150	0.5865	0.0515
155	0.4726	0.0482
160	0.4726	0.0452
165	0.5865	0.0425
170	0.7475	0.04
175	0.9862	0.0378
180	1.3628	0.0357
185	2.0096	0.0338
190	3.2676	0.032
195	6.2276	0.0304
200	15.3098	0.0289
205	29.9743	0.0275
210	4.9127	0.0262
215	29.9742	0.025
220	15.3098	0.0239
225	6.2276	0.0228
230	3.2676	0.0219
235	2.0096	0.0209
240	1.3628	0.0201
245	0.9862	0.0193
250	0.7475	0.0185
255	0.5865	0.0178
260	0.4726	0.0171
265	0.0165	0.0165
270	0.0159	0.0159
275	0.0153	0.0153
280	0.0147	0.0147
285	0.0142	0.0142
290	0.0137	0.0137
295	0.0133	0.0133
300	0.0128	0.0128
305	0.0124	0.0124
310	0.012	0.012
315	0.0116	0.0116
320	0.0113	0.0113
325	0.0109	0.0109
330	0.0106	0.0106
335	0.0103	0.0103
340	0.01	0.01
345	0.0097	0.0097
350	0.0094	0.0094
355	0.0092	0.0092
360	0.0089	0.0089
365	0.0087	0.0087

370	0.0084	0.0084
375	0.0082	0.0082
380	0.008	0.008
385	0.0078	0.0078
390	0.0076	0.0076
395	0.0074	0.0074
400	0.0072	0.0072
405	0.007	0.007
410	0.0069	0.0069
415	0.0067	0.0067
420	0.0066	0.0066
425	0.0064	0.0064
430	0.0062	0.0062
435	0.0061	0.0061
440	0.006	0.006
445	0.0058	0.0058
450	0.0057	0.0057
455	0.0056	0.0056
460	0.0055	0.0055
465	0.0053	0.0053
470	0.0052	0.0052
475	0.0051	0.0051
480	0.005	0.005
485	0.0049	0.0049
490	0.0048	0.0048
495	0.0047	0.0047
500	0.0046	0.0046

Peak	value	found	at:
X	Y=0.0	Y=1.0	
(feet)	(feet)	(feet)	
B(mG)	B(mG)		
	-5	29.9743	19.3417



NYPA-500.txt

PHASE ANGLE (DEGREES)	CURRENT CENTER OF TOWER (kAmps)	CORONA LOSSES (KW/MI)	HEIGHT (FEET)	GRADIENT (KV/CM)	DIAM. (IN)	SUBCON	SPACING (IN)	L-N (KV)
NYPA 0.00	1.40	75.00 5.523	98.00	14.49	1.11	2	18.00	199.19
NYPA -120.00	1.40	75.00 8.717	63.00	15.55	1.11	2	18.00	199.19
NYPA 120.00	1.40	75.00 10.227	28.00	15.93	1.11	2	18.00	199.19
NYPA 0.00	1.40	175.00 4.244	98.00	13.92	1.11	2	18.00	199.19
NYPA -120.00	1.40	175.00 8.888	63.00	15.59	1.11	2	18.00	199.19
NYPA 120.00	1.40	175.00 10.363	28.00	15.96	1.11	2	18.00	199.19
SW 0.00	0.00	75.00 0.000	125.00	10.94	0.39	1	0.00	0.00
SW 0.00	0.00	100.00 0.000	125.00	9.54	0.39	1	0.00	0.00

AN MICROPHONE HT.= 5.0 FT, RI ANT. HT.= 6.6 FT, TV ANT. HT.= 9.8 FT, ALTITUDE= 0.0 FT

RI FREQ= 1.000 MHZ, TV FREQ= 75.000 MHZ, WIND VEL.(OZ)= 0.500 MPH, GROUND CONDUCTIVITY = 10.0 MMHOS/M

E-FIELD TRANSDUCER HT.= 3.3FT, B-FIELD TRANSDUCER HT.= 3.3FT

LATERAL DIST OZONE FROM RATE OF REFERENCE 0. FT LEVEL (FEET)	AUDIBLE NOISE (RAIN) ELECTRIC FIELD DBA KV/M	RADIO INTERFERENCE (FAIR) MAGNETIC FIELD DBA GAUSS	(RAIN) (FAIR) DBUV/M	TVI TOTAL RAIN DBUV/M	FOR RAIN 1.00 IN/HR AT PPB
-500.0 0.000000	33.7 0.038	8.7 0.00287	31.1 14.1	-3.2	
-495.0 0.000000	33.7 0.039	8.7 0.00292	31.2 14.2	-3.1	
-490.0 0.000000	33.8 0.040	8.8 0.00296	31.3 14.3	-2.9	
-485.0 0.000000	33.8 0.040	8.8 0.00301	31.4 14.4	-2.8	
-480.0 0.000000	33.8 0.041	8.8 0.00306	31.4 14.4	-2.7	
-475.0 0.000000	33.9 0.042	8.9 0.00312	31.5 14.5	-2.6	



NYPA-500.txt

-470.0	33.9	8.9	31.6	14.6	-2.6
0.000000	0.042	0.00317			
-465.0	34.0	9.0	31.7	14.7	-2.5
0.000000	0.043	0.00322			
-460.0	34.0	9.0	31.8	14.8	-2.4
0.000000	0.044	0.00328			
-455.0	34.1	9.1	31.9	14.9	-2.3
0.000000	0.044	0.00334			
-450.0	34.1	9.1	31.9	14.9	-2.2
0.000000	0.045	0.00339			
-445.0	34.1	9.1	32.0	15.0	-2.2
0.000000	0.046	0.00345			
-440.0	34.2	9.2	32.1	15.1	-2.1
0.000000	0.047	0.00352			
-435.0	34.2	9.2	32.2	15.2	-2.0
0.000000	0.047	0.00358			
-430.0	34.3	9.3	32.3	15.3	-1.9
0.000000	0.048	0.00364			
-425.0	34.3	9.3	32.4	15.4	-1.8
0.000000	0.049	0.00371			
-420.0	34.4	9.4	32.5	15.5	-1.7
0.000000	0.050	0.00378			
-415.0	34.4	9.4	32.6	15.6	-1.7
0.000000	0.051	0.00385			
-410.0	34.5	9.5	32.7	15.7	-1.6
0.000000	0.052	0.00392			
-405.0	34.5	9.5	32.8	15.8	-1.5
0.000000	0.053	0.00400			
-400.0	34.6	9.6	32.9	15.9	-1.4
0.000000	0.054	0.00408			
-395.0	34.6	9.6	33.0	16.0	-1.3
0.000000	0.055	0.00416			
-390.0	34.7	9.7	33.1	16.1	-1.2
0.000000	0.056	0.00424			
-385.0	34.7	9.7	33.2	16.2	-1.1
0.000000	0.057	0.00432			
-380.0	34.7	9.7	33.3	16.3	-1.0
0.000000	0.058	0.00441			
-375.0	34.8	9.8	33.4	16.4	-0.9
0.000000	0.059	0.00450			
-370.0	34.8	9.8	33.5	16.5	-0.8
0.000000	0.060	0.00459			
-365.0	34.9	9.9	33.6	16.6	-0.7
0.000000	0.061	0.00469			
-360.0	35.0	10.0	33.7	16.7	-0.6
0.000000	0.062	0.00478			
-355.0	35.0	10.0	33.8	16.8	-0.5
0.000000	0.064	0.00488			

NYPA-500.txt

-350.0	35.1	10.1	33.9	16.9	-0.4
0.000000	0.065	0.00499			
-345.0	35.1	10.1	34.0	17.0	-0.3
0.000000	0.066	0.00510			
-340.0	35.2	10.2	34.1	17.1	-0.2
0.000000	0.067	0.00521			
-335.0	35.2	10.2	34.2	17.2	-0.1
0.000000	0.069	0.00532			
-330.0	35.3	10.3	34.3	17.3	-0.0
0.000000	0.070	0.00544			
-325.0	35.3	10.3	34.5	17.5	0.1
0.000000	0.072	0.00556			
-320.0	35.4	10.4	34.6	17.6	0.2
0.000000	0.073	0.00569			
-315.0	35.4	10.4	34.7	17.7	0.3
0.000000	0.075	0.00582			
-310.0	35.5	10.5	34.8	17.8	0.4
0.000000	0.076	0.00596			
-305.0	35.6	10.6	34.9	17.9	0.5
0.000000	0.078	0.00610			
-300.0	35.6	10.6	35.1	18.1	0.6
0.000000	0.080	0.00625			
-295.0	35.7	10.7	35.2	18.2	0.7
0.000000	0.081	0.00640			
-290.0	35.7	10.7	35.3	18.3	0.9
0.000000	0.083	0.00655			
-285.0	35.8	10.8	35.5	18.5	1.0
0.000000	0.085	0.00672			
-280.0	35.9	10.9	35.6	18.6	1.1
0.000000	0.087	0.00689			
-275.0	35.9	10.9	35.7	18.7	1.2
0.000000	0.089	0.00706			
-270.0	36.0	11.0	35.9	18.9	1.3
0.000000	0.091	0.00724			
-265.0	36.0	11.0	36.0	19.0	1.5
0.000000	0.093	0.00743			
-260.0	36.1	11.1	36.2	19.2	1.6
0.000000	0.095	0.00763			
-255.0	36.2	11.2	36.3	19.3	1.7
0.000000	0.098	0.00783			
-250.0	36.2	11.2	36.5	19.5	1.8
0.000000	0.100	0.00805			
-245.0	36.3	11.3	36.6	19.6	2.0
0.000000	0.103	0.00827			
-240.0	36.4	11.4	36.8	19.8	2.1
0.000000	0.105	0.00850			
-235.0	36.5	11.5	36.9	19.9	2.2
0.000000	0.108	0.00874			

NYPA-500.txt

-230.0	36.5	11.5	37.1	20.1	2.4
0.000000	0.110	0.00899			
-225.0	36.6	11.6	37.3	20.3	2.5
0.000000	0.113	0.00925			
-220.0	36.7	11.7	37.4	20.4	2.7
0.000000	0.116	0.00953			
-215.0	36.7	11.7	37.6	20.6	2.9
0.000000	0.119	0.00981			
-210.0	36.8	11.8	37.8	20.8	3.2
0.000000	0.122	0.01011			
-205.0	36.9	11.9	38.0	21.0	3.5
0.000000	0.126	0.01042			
-200.0	37.0	12.0	38.2	21.2	3.9
0.000000	0.129	0.01075			
-195.0	37.0	12.0	38.4	21.4	4.2
0.000000	0.132	0.01110			
-190.0	37.1	12.1	38.6	21.6	4.5
0.000000	0.136	0.01146			
-185.0	37.2	12.2	38.8	21.8	4.8
0.000000	0.140	0.01183			
-180.0	37.3	12.3	39.0	22.0	5.2
0.000000	0.144	0.01223			
-175.0	37.4	12.4	39.2	22.2	5.5
0.000000	0.148	0.01265			
-170.0	37.5	12.5	39.4	22.4	5.7
0.000000	0.152	0.01309			
-165.0	37.5	12.5	39.6	22.6	5.9
0.000000	0.156	0.01355			
-160.0	37.6	12.6	39.8	22.8	6.0
0.000000	0.161	0.01404			
-155.0	37.7	12.7	40.0	23.0	6.2
0.000000	0.166	0.01455			
-150.0	37.8	12.8	40.3	23.3	6.4
0.000000	0.171	0.01509			
-145.0	37.9	12.9	40.5	23.5	6.6
0.000000	0.176	0.01566			
-140.0	38.0	13.0	40.8	23.8	6.8
0.000000	0.181	0.01627			
-135.0	38.1	13.1	41.0	24.0	7.0
0.000000	0.186	0.01691			
-130.0	38.2	13.2	41.3	24.3	7.2
0.000000	0.192	0.01759			
-125.0	38.3	13.3	41.6	24.6	7.4
0.000000	0.198	0.01831			
-120.0	38.4	13.4	41.8	24.8	7.6
0.000000	0.204	0.01908			
-115.0	38.5	13.5	42.1	25.1	7.9
0.000000	0.210	0.01989			

NYPA-500.txt

-110.0	38.6	13.6	42.4	25.4	8.1
0.000000	0.216	0.02076			
-105.0	38.7	13.7	42.7	25.7	8.3
0.000000	0.223	0.02168			
-100.0	38.8	13.8	43.0	26.0	8.6
0.000000	0.229	0.02267			
-95.0	39.0	14.0	43.4	26.4	8.8
0.000000	0.236	0.02372			
-90.0	39.1	14.1	43.7	26.7	9.1
0.000000	0.243	0.02485			
-85.0	39.2	14.2	44.1	27.1	9.3
0.000000	0.250	0.02606			
-80.0	39.3	14.3	44.4	27.4	9.6
0.000000	0.257	0.02736			
-75.0	39.5	14.5	44.8	27.8	9.9
0.000000	0.264	0.02876			
-70.0	39.6	14.6	45.2	28.2	10.2
0.000000	0.271	0.03026			
-65.0	39.7	14.7	45.6	28.6	10.5
0.000000	0.277	0.03188			
-60.0	39.9	14.9	46.0	29.0	10.8
0.000000	0.283	0.03363			
-55.0	40.0	15.0	46.4	29.4	11.1
0.000000	0.289	0.03553			
-50.0	40.2	15.2	46.9	29.9	11.5
0.000000	0.294	0.03759			
-45.0	40.3	15.3	47.3	30.3	11.8
0.000000	0.297	0.03982			
-40.0	40.5	15.5	47.8	30.8	12.2
0.000000	0.300	0.04226			
-35.0	40.6	15.6	48.3	31.3	12.5
0.000000	0.301	0.04492			
-30.0	40.8	15.8	48.8	31.8	12.9
0.000000	0.299	0.04782			
-25.0	41.0	16.0	49.3	32.3	13.3
0.000000	0.295	0.05101			
-20.0	41.1	16.1	49.9	32.9	13.8
0.000000	0.288	0.05451			
-15.0	41.3	16.3	50.5	33.5	14.2
0.000000	0.277	0.05837			
-10.0	41.5	16.5	51.1	34.1	14.7
0.000000	0.262	0.06264			
-5.0	41.7	16.7	51.7	34.7	15.2
0.000000	0.243	0.06737			

1



NYPAA0-495.txt

PHASE ANGLE (DEGREES)	CURRENT CENTER OF TOWER (kAmps)	CORONA LOSSES (KW/MI)	HEIGHT (FEET)	GRADIENT (KV/CM)	DIAM. (IN)	SUBCON	SPACING (IN)	L-N (KV)
NYPAA 0.00	1.40	75.00 5.523	98.00	14.49	1.11	2	18.00	199.19
NYPAA -120.00	1.40	75.00 8.717	63.00	15.55	1.11	2	18.00	199.19
NYPAA 120.00	1.40	75.00 10.227	28.00	15.93	1.11	2	18.00	199.19
NYPAA 0.00	1.40	175.00 4.244	98.00	13.92	1.11	2	18.00	199.19
NYPAA -120.00	1.40	175.00 8.888	63.00	15.59	1.11	2	18.00	199.19
NYPAA 120.00	1.40	175.00 10.363	28.00	15.96	1.11	2	18.00	199.19
SW 0.00	0.00	75.00 0.000	125.00	10.94	0.39	1	0.00	0.00
SW 0.00	0.00	100.00 0.000	125.00	9.54	0.39	1	0.00	0.00

AN MICROPHONE HT.= 5.0 FT, RI ANT. HT.= 6.6 FT, TV ANT. HT.= 9.8 FT, ALTITUDE= 0.0 FT

RI FREQ= 1.000 MHZ, TV FREQ= 75.000 MHZ, WIND VEL.(OZ)= 0.500 MPH, GROUND CONDUCTIVITY = 10.0 MMHOS/M

E-FIELD TRANSDUCER HT.= 3.3FT, B-FIELD TRANSDUCER HT.= 3.3FT

LATERAL DIST FROM RATE OF REFERENCE OZONE (FEET)	AUDIBLE NOISE (RAIN) ELECTRIC FIELD DBA KV/M	RADIO INTERFERENCE (FAIR) MAGNETIC FIELD DBA GAUSS	(RAIN) (FAIR) DBUV/M	TVI TOTAL RAIN DBUV/M	FOR RAIN 1.00 IN/HR AT PPB
0.0	41.9	16.9	52.3 35.3	15.7	
0.000000	0.223	0.07263			
5.0	42.2	17.2	53.0 36.0	16.3	
0.000000	0.211	0.07850			
10.0	42.4	17.4	53.6 36.6	16.9	
0.000000	0.227	0.08508			
15.0	42.6	17.6	54.3 37.3	17.5	
0.000000	0.294	0.09246			
20.0	42.9	17.9	55.0 38.0	18.2	
0.000000	0.419	0.10079			
25.0	43.2	18.2	55.7 38.7	19.0	
0.000000	0.606	0.11021			

NYPAA0-495.txt

30.0	43.4	18.4	56.6	39.6	19.8
0.000000	0.866	0.12089			
35.0	43.7	18.7	58.2	41.2	20.6
0.000000	1.215	0.13299			
40.0	44.1	19.1	59.9	42.9	21.6
0.000000	1.678	0.14666			
45.0	44.4	19.4	61.7	44.7	22.6
0.000000	2.280	0.16197			
50.0	44.7	19.7	63.6	46.6	23.7
0.000000	3.044	0.17875			
55.0	45.1	20.1	65.6	48.6	24.8
0.000000	3.973	0.19641			
60.0	45.5	20.5	67.5	50.5	26.0
0.000000	5.019	0.21348			
65.0	45.8	20.8	69.3	52.3	27.1
0.000000	6.053	0.22735			
70.0	46.0	21.0	70.5	53.5	28.0
0.000000	6.846	0.23431			
75.0	46.1	21.1	71.0	54.0	28.3
0.000000	7.153	0.23096			
80.0	46.1	21.1	70.5	53.5	28.0
0.406910	6.863	0.21643			
85.0	46.0	21.0	69.3	52.3	27.1
0.685876	6.091	0.19329			
90.0	45.7	20.7	67.5	50.5	26.0
0.724500	5.086	0.16579			
95.0	45.5	20.5	65.6	48.6	24.8
0.706298	4.079	0.13755			
100.0	45.3	20.3	63.6	46.6	23.7
0.667207	3.207	0.11067			
105.0	45.1	20.1	61.7	44.7	22.6
0.622424	2.522	0.08593			
110.0	45.0	20.0	59.9	42.9	21.6
0.578515	2.026	0.06355			
115.0	44.9	19.9	58.2	41.2	20.6
0.537961	1.700	0.04425			
120.0	44.8	19.8	56.6	39.6	19.8
0.501433	1.517	0.03397			
125.0	44.8	19.8	55.8	38.8	19.1
0.468856	1.457	0.03240			
130.0	44.8	19.8	56.7	39.7	19.9
0.439878	1.510	0.03397			
135.0	44.9	19.9	58.3	41.3	20.7
0.414076	1.686	0.04425			
140.0	45.0	20.0	60.0	43.0	21.7
0.391036	2.006	0.06355			
145.0	45.1	20.1	61.8	44.8	22.7
0.370386	2.498	0.08593			

NYPA0-495.txt

150.0	45.3	20.3	63.7	46.7	23.8
0.351804	3.180	0.11067			
155.0	45.6	20.6	65.7	48.7	24.9
0.335012	4.049	0.13755			
160.0	45.8	20.8	67.6	50.6	26.1
0.319776	5.054	0.16579			
165.0	46.0	21.0	69.4	52.4	27.2
0.305897	6.057	0.19329			
170.0	46.1	21.1	70.6	53.6	28.1
0.293207	6.828	0.21643			
175.0	46.2	21.2	71.1	54.1	28.4
0.281563	7.114	0.23096			
180.0	46.1	21.1	70.6	53.6	28.1
0.684841	6.802	0.23431			
185.0	45.8	20.8	69.4	52.4	27.2
0.958906	6.002	0.22735			
190.0	45.5	20.5	67.6	50.6	26.1
0.984457	4.961	0.21348			
195.0	45.1	20.1	65.7	48.7	24.9
0.950136	3.907	0.19641			
200.0	44.8	19.8	63.7	46.7	23.8
0.896954	2.971	0.17875			
205.0	44.4	19.4	61.8	44.8	22.7
0.840827	2.199	0.16197			
210.0	44.1	19.1	60.0	43.0	21.7
0.787713	1.590	0.14666			
215.0	43.8	18.8	58.3	41.3	20.7
0.739457	1.121	0.13299			
220.0	43.4	18.4	56.7	39.7	19.9
0.696277	0.768	0.12089			
225.0	43.2	18.2	55.8	38.8	19.1
0.657803	0.506	0.11021			
230.0	42.9	17.9	55.1	38.1	18.3
0.623492	0.323	0.10079			
235.0	42.6	17.6	54.5	37.5	17.6
0.592796	0.217	0.09246			
240.0	42.4	17.4	53.8	36.8	17.0
0.565217	0.199	0.08508			
245.0	42.2	17.2	53.1	36.1	16.4
0.540325	0.232	0.07850			
250.0	41.9	16.9	52.5	35.5	15.8
0.517752	0.271	0.07263			
255.0	41.7	16.7	51.8	34.8	15.3
0.497192	0.305	0.06737			
260.0	41.5	16.5	51.2	34.2	14.8
0.478383	0.332	0.06264			
265.0	41.3	16.3	50.6	33.6	14.3
0.461108	0.351	0.05837			



NYPAA0-495.txt

270.0	41.1	16.1	50.0	33.0	13.9
0.445182	0.364	0.05451			
275.0	40.9	15.9	49.5	32.5	13.4
0.430449	0.372	0.05101			
280.0	40.8	15.8	49.0	32.0	13.0
0.416775	0.375	0.04782			
285.0	40.6	15.6	48.4	31.4	12.6
0.404046	0.376	0.04492			
290.0	40.4	15.4	47.9	30.9	12.3
0.392163	0.374	0.04226			
295.0	40.3	15.3	47.5	30.5	11.9
0.381042	0.369	0.03982			
300.0	40.1	15.1	47.0	30.0	11.6
0.370608	0.363	0.03759			
305.0	40.0	15.0	46.6	29.6	11.2
0.360798	0.356	0.03553			
310.0	39.8	14.8	46.1	29.1	10.9
0.351553	0.349	0.03363			
315.0	39.7	14.7	45.7	28.7	10.6
0.342826	0.340	0.03188			
320.0	39.6	14.6	45.3	28.3	10.3
0.334570	0.332	0.03026			
325.0	39.4	14.4	44.9	27.9	10.0
0.326749	0.323	0.02876			
330.0	39.3	14.3	44.6	27.6	9.7
0.319325	0.314	0.02736			
335.0	39.2	14.2	44.2	27.2	9.4
0.312270	0.304	0.02606			
340.0	39.1	14.1	43.9	26.9	9.2
0.305554	0.295	0.02485			
345.0	38.9	13.9	43.5	26.5	8.9
0.299152	0.286	0.02372			
350.0	38.8	13.8	43.2	26.2	8.7
0.293043	0.278	0.02267			
355.0	38.7	13.7	42.9	25.9	8.4
0.287205	0.269	0.02168			
360.0	38.6	13.6	42.6	25.6	8.2
0.281620	0.261	0.02076			
365.0	38.5	13.5	42.3	25.3	8.0
0.276272	0.253	0.01989			
370.0	38.4	13.4	42.0	25.0	7.7
0.271144	0.245	0.01908			
375.0	38.3	13.3	41.7	24.7	7.5
0.266224	0.237	0.01831			
380.0	38.2	13.2	41.4	24.4	7.3
0.261497	0.230	0.01759			
385.0	38.1	13.1	41.2	24.2	7.1
0.256953	0.223	0.01691			

NYPAA0-495.txt

390.0	38.0	13.0	40.9	23.9	6.9
0.252580	0.216	0.01627			
395.0	37.9	12.9	40.7	23.7	6.7
0.248369	0.209	0.01566			
400.0	37.8	12.8	40.4	23.4	6.5
0.244310	0.203	0.01509			
405.0	37.7	12.7	40.2	23.2	6.3
0.240395	0.197	0.01455			
410.0	37.6	12.6	40.0	23.0	6.1
0.236616	0.191	0.01404			
415.0	37.5	12.5	39.8	22.8	6.0
0.232966	0.185	0.01355			
420.0	37.4	12.4	39.5	22.5	5.8
0.229439	0.180	0.01309			
425.0	37.4	12.4	39.3	22.3	5.6
0.226026	0.174	0.01265			
430.0	37.3	12.3	39.1	22.1	5.3
0.222724	0.169	0.01223			
435.0	37.2	12.2	38.9	21.9	4.9
0.219527	0.164	0.01183			
440.0	37.1	12.1	38.7	21.7	4.6
0.216429	0.160	0.01146			
445.0	37.0	12.0	38.5	21.5	4.3
0.213425	0.155	0.01110			
450.0	36.9	11.9	38.3	21.3	4.0
0.210512	0.151	0.01075			
455.0	36.9	11.9	38.1	21.1	3.7
0.207685	0.147	0.01042			
460.0	36.8	11.8	38.0	21.0	3.3
0.204940	0.143	0.01011			
465.0	36.7	11.7	37.8	20.8	3.0
0.202274	0.139	0.00981			
470.0	36.6	11.6	37.6	20.6	2.8
0.199682	0.135	0.00953			
475.0	36.6	11.6	37.4	20.4	2.7
0.197163	0.132	0.00925			
480.0	36.5	11.5	37.3	20.3	2.5
0.194712	0.128	0.00899			
485.0	36.4	11.4	37.1	20.1	2.4
0.192327	0.125	0.00874			
490.0	36.4	11.4	36.9	19.9	2.3
0.190006	0.122	0.00850			
495.0	36.3	11.3	36.8	19.8	2.1
0.187745	0.118	0.00827			

1



NYP500.txt

PHASE ANGLE (DEGREES)	CURRENT CENTER OF TOWER (kAmps)	CORONA LOSSES (KW/MI)	HEIGHT (FEET)	GRADIENT (KV/CM)	DIAM. (IN)	SUBCON	SPACING (IN)	L-N (KV)
NYP500	1.40	75.00	98.00	14.49	1.11	2	18.00	199.19
-120.00	1.40	8.717	63.00	15.55	1.11	2	18.00	199.19
120.00	1.40	10.227	28.00	15.93	1.11	2	18.00	199.19
NYP500	1.40	175.00	98.00	13.92	1.11	2	18.00	199.19
-120.00	1.40	8.888	63.00	15.59	1.11	2	18.00	199.19
120.00	1.40	10.363	28.00	15.96	1.11	2	18.00	199.19
SW	0.00	75.00	125.00	10.94	0.39	1	0.00	0.00
SW	0.00	100.00	125.00	9.54	0.39	1	0.00	0.00

AN MICROPHONE HT.= 5.0 FT, RI ANT. HT.= 6.6 FT, TV ANT. HT.= 9.8 FT, ALTITUDE= 0.0 FT

RI FREQ= 1.000 MHZ, TV FREQ= 75.000 MHZ, WIND VEL.(OZ)= 0.500 MPH, GROUND CONDUCTIVITY = 10.0 MMHOS/M

E-FIELD TRANSDUCER HT.= 3.3FT, B-FIELD TRANSDUCER HT.= 3.3FT

LATERAL DIST FROM RATE OF REFERENCE OZONE (FEET)	AUDIBLE NOISE (RAIN) ELECTRIC FIELD DBA KV/M	RADIO INTERFERENCE (FAIR) MAGNETIC FIELD DBA GAUSS	TVI TOTAL RAIN DBUV/M	FOR RAIN 1.00 IN/HR AT PPB	
500.0	36.2	11.2	36.6	19.6	2.0
0.185542	0.115	0.00805			
505.0	36.2	11.2	36.5	19.5	1.9
0.183395	0.113	0.00783			
510.0	36.1	11.1	36.3	19.3	1.7
0.181301	0.110	0.00763			
515.0	36.0	11.0	36.2	19.2	1.6
0.179260	0.107	0.00743			
520.0	36.0	11.0	36.0	19.0	1.5
0.177268	0.105	0.00724			
525.0	35.9	10.9	35.9	18.9	1.4
0.175323	0.102	0.00706			

NYP500.txt

530.0	35.8	10.8	35.8	18.8	1.3
0.173425	0.100	0.00689			
535.0	35.8	10.8	35.6	18.6	1.1
0.171571	0.097	0.00672			
540.0	35.7	10.7	35.5	18.5	1.0
0.169760	0.095	0.00655			
545.0	35.7	10.7	35.3	18.3	0.9
0.167991	0.093	0.00640			
550.0	35.6	10.6	35.2	18.2	0.8
0.166261	0.091	0.00625			
555.0	35.5	10.5	35.1	18.1	0.7
0.164570	0.089	0.00610			
560.0	35.5	10.5	35.0	18.0	0.6
0.162915	0.087	0.00596			
565.0	35.4	10.4	34.8	17.8	0.5
0.161297	0.085	0.00582			
570.0	35.4	10.4	34.7	17.7	0.3
0.159713	0.083	0.00569			
575.0	35.3	10.3	34.6	17.6	0.2
0.158163	0.081	0.00556			
580.0	35.3	10.3	34.5	17.5	0.1
0.156646	0.079	0.00544			
585.0	35.2	10.2	34.3	17.3	0.0
0.155160	0.078	0.00532			
590.0	35.1	10.1	34.2	17.2	-0.1
0.153704	0.076	0.00521			
595.0	35.1	10.1	34.1	17.1	-0.2
0.152278	0.075	0.00510			
600.0	35.0	10.0	34.0	17.0	-0.3
0.150880	0.073	0.00499			
605.0	35.0	10.0	33.9	16.9	-0.4
0.149510	0.072	0.00488			
610.0	34.9	9.9	33.8	16.8	-0.5
0.148167	0.070	0.00478			
615.0	34.9	9.9	33.7	16.7	-0.6
0.146850	0.069	0.00469			
620.0	34.8	9.8	33.6	16.6	-0.7
0.145558	0.067	0.00459			
625.0	34.8	9.8	33.5	16.5	-0.8
0.144291	0.066	0.00450			
630.0	34.7	9.7	33.4	16.4	-0.9
0.143047	0.065	0.00441			
635.0	34.7	9.7	33.3	16.3	-1.0
0.141827	0.063	0.00432			
640.0	34.6	9.6	33.1	16.1	-1.0
0.140629	0.062	0.00424			
645.0	34.6	9.6	33.0	16.0	-1.1
0.139453	0.061	0.00416			

NYP500.txt

650.0	34.5	9.5	32.9	15.9	-1.2
0.138298	0.060	0.00408			
655.0	34.5	9.5	32.9	15.9	-1.3
0.137163	0.059	0.00400			
660.0	34.4	9.4	32.8	15.8	-1.4
0.136049	0.058	0.00392			
665.0	34.4	9.4	32.7	15.7	-1.5
0.134955	0.057	0.00385			
670.0	34.4	9.4	32.6	15.6	-1.6
0.133879	0.056	0.00378			
675.0	34.3	9.3	32.5	15.5	-1.7
0.132822	0.055	0.00371			
680.0	34.3	9.3	32.4	15.4	-1.8
0.131782	0.054	0.00364			
685.0	34.2	9.2	32.3	15.3	-1.8
0.130761	0.053	0.00358			
690.0	34.2	9.2	32.2	15.2	-1.9
0.129756	0.052	0.00352			
695.0	34.1	9.1	32.1	15.1	-2.0
0.128768	0.051	0.00345			
700.0	34.1	9.1	32.0	15.0	-2.1
0.127797	0.050	0.00339			
705.0	34.0	9.0	31.9	14.9	-2.2
0.126841	0.049	0.00334			
710.0	34.0	9.0	31.8	14.8	-2.3
0.125900	0.048	0.00328			
715.0	34.0	9.0	31.7	14.7	-2.3
0.124975	0.047	0.00322			
720.0	33.9	8.9	31.7	14.7	-2.4
0.124064	0.047	0.00317			
725.0	33.9	8.9	31.6	14.6	-2.5
0.123167	0.046	0.00312			
730.0	33.8	8.8	31.5	14.5	-2.6
0.122285	0.045	0.00306			
735.0	33.8	8.8	31.4	14.4	-2.6
0.121416	0.044	0.00301			
740.0	33.8	8.8	31.3	14.3	-2.8
0.120560	0.044	0.00296			
745.0	33.7	8.7	31.2	14.2	-2.9
0.119718	0.043	0.00292			
750.0	33.7	8.7	31.2	14.2	-3.1
0.118888	0.042	0.00287			
755.0	33.6	8.6	31.1	14.1	-3.2
0.118071	0.042	0.00282			
760.0	33.6	8.6	31.0	14.0	-3.4
0.117265	0.041	0.00278			
765.0	33.6	8.6	30.9	13.9	-3.5
0.116472	0.040	0.00274			

NYP500.txt

770.0	33.5	8.5	30.9	13.9	-3.7
0.115690	0.040	0.00269			
775.0	33.5	8.5	30.8	13.8	-3.8
0.114919	0.039	0.00265			
780.0	33.4	8.4	30.7	13.7	-3.9
0.114160	0.039	0.00261			
785.0	33.4	8.4	30.6	13.6	-4.1
0.113411	0.038	0.00257			
790.0	33.4	8.4	30.5	13.5	-4.2
0.112673	0.037	0.00253			
795.0	33.3	8.3	30.5	13.5	-4.4
0.111945	0.037	0.00250			
800.0	33.3	8.3	30.4	13.4	-4.5
0.111227	0.036	0.00246			
805.0	33.3	8.3	30.3	13.3	-4.6
0.110520	0.036	0.00242			
810.0	33.2	8.2	30.3	13.3	-4.8
0.109822	0.035	0.00239			
815.0	33.2	8.2	30.2	13.2	-4.9
0.109133	0.035	0.00235			
820.0	33.1	8.1	30.1	13.1	-5.1
0.108454	0.034	0.00232			
825.0	33.1	8.1	30.0	13.0	-5.2
0.107784	0.034	0.00228			
830.0	33.1	8.1	30.0	13.0	-5.3
0.107123	0.033	0.00225			
835.0	33.0	8.0	29.9	12.9	-5.4
0.106470	0.033	0.00222			
840.0	33.0	8.0	29.8	12.8	-5.6
0.105826	0.032	0.00219			
845.0	33.0	8.0	29.8	12.8	-5.7
0.105191	0.032	0.00216			
850.0	32.9	7.9	29.7	12.7	-5.8
0.104564	0.031	0.00213			
855.0	32.9	7.9	29.6	12.6	-6.0
0.103945	0.031	0.00210			
860.0	32.9	7.9	29.6	12.6	-6.1
0.103333	0.031	0.00207			
865.0	32.8	7.8	29.5	12.5	-6.2
0.102730	0.030	0.00204			
870.0	32.8	7.8	29.4	12.4	-6.3
0.102134	0.030	0.00202			
875.0	32.8	7.8	29.4	12.4	-6.5
0.101545	0.029	0.00199			
880.0	32.7	7.7	29.3	12.3	-6.6
0.100964	0.029	0.00196			
885.0	32.7	7.7	29.2	12.2	-6.7
0.100390	0.029	0.00194			

NYP500.txt

890.0	32.7	7.7	29.2	12.2	-6.8
0.099823	0.028	0.00191			
895.0	32.6	7.6	29.1	12.1	-7.0
0.099263	0.028	0.00189			
900.0	32.6	7.6	29.1	12.1	-7.1
0.098710	0.027	0.00186			
905.0	32.6	7.6	29.0	12.0	-7.2
0.098163	0.027	0.00184			
910.0	32.5	7.5	28.9	11.9	-7.3
0.097623	0.027	0.00182			
915.0	32.5	7.5	28.9	11.9	-7.4
0.097090	0.026	0.00179			
920.0	32.5	7.5	28.8	11.8	-7.5
0.096562	0.026	0.00177			
925.0	32.4	7.4	28.7	11.7	-7.7
0.096041	0.026	0.00175			
930.0	32.4	7.4	28.7	11.7	-7.8
0.095526	0.025	0.00173			
935.0	32.4	7.4	28.6	11.6	-7.9
0.095017	0.025	0.00170			
940.0	32.4	7.4	28.6	11.6	-8.0
0.094513	0.025	0.00168			
945.0	32.3	7.3	28.5	11.5	-8.1
0.094016	0.025	0.00166			
950.0	32.3	7.3	28.4	11.4	-8.2
0.093524	0.024	0.00164			
955.0	32.3	7.3	28.4	11.4	-8.3
0.093037	0.024	0.00162			
960.0	32.2	7.2	28.3	11.3	-8.4
0.092556	0.024	0.00160			
965.0	32.2	7.2	28.3	11.3	-8.6
0.092081	0.023	0.00158			
970.0	32.2	7.2	28.2	11.2	-8.7
0.091610	0.023	0.00157			
975.0	32.1	7.1	28.2	11.2	-8.8
0.091145	0.023	0.00155			
980.0	32.1	7.1	28.1	11.1	-8.9
0.090685	0.023	0.00153			
985.0	32.1	7.1	28.0	11.0	-9.0
0.090230	0.022	0.00151			
990.0	32.1	7.1	28.0	11.0	-9.1
0.089780	0.022	0.00149			
995.0	32.0	7.0	27.9	10.9	-9.2
0.089335	0.022	0.00148			

1